

Class 1E Cable Qualification to the Latest IEEE Standards

IEEE NPEC SC-2 Meeting

April 7-8, 2009

Knoxville, TN

Presented by: John Cancelosi

**The Okonite Company
Ramsey, NJ**


Overview

- **History of Class 1E Testing**
- **IEEE 383-1974 vs. IEEE 383-2003**
 - **DBE LOCA Test**
 - **Vertical Tray Flame Test**
- **Qualification Test Program**
 - **Specimen Selection**
 - **Aging**
 - **LOCA & HELB**
 - **Flame Tests**

Early Cable Qualification Tests (Pre IEEE 383-1974)

- **Early 1960's - Effects of radiation**
- **'60s – early '70s**
 - **Thermal aging to ICEA requirements**
 - **1 week @ 121 C**
 - **Radiation: 100 Mrads gamma**
 - **Mild LOCA profile**

Early Cable Qualification Tests Pre IEEE 383-1974



IEEE Standards

- **IEEE 323-1974** – Std for Qualifying Class 1E Equipment for Nuclear Power Generating Stations
- **IEEE 383-1974** – Std for Type Test of Class 1E Electric Cables, Field Splices and Connections for Nuclear Power Generating Stations

IEEE 383-1974

Qualification (Type) Tests

- Tests to Qualify for Normal Operation
- Tests to Qualify for Design Basis Event
 - LOCA
 - HELB / MSLB
- Tests to Qualify for Design Basis Event –
Fire

IEEE 383-1974

Tests to Qualify for Normal Operation

- Made, tested and qualified to Industry Standards ICEA - AEIC - NEMA
- Long Term Physical Aging Properties
- Thermal & Radiation Exposure
 - 1) Aging to “End of Life” condition
 - 2) Radiation Exposure (**50 MRads**)
 - 3) Mechanical & Electrical Withstand


IEEE 383-1974

Tests to Qualify for DBE -LOCA

- **Thermal & Radiation Exposure**
 - Aging to “End of Life” condition
 - Radiation Exposure
 - Normal Life Dosage (50 MRads)
 - One accident dose (150 MRads)
- **Loss of Coolant Accident simulation**
 - Temperature, Pressure & Chem spray
- **Post LOCA Simulation test**
 - Mechanical & Electrical Withstand

Cable Qualification Test Profile for Life & LOCA Conditions

LEGEND: ▲ INSULATION RESISTANCE MEASUREMENT; ○ AC WITHSTAND TEST, 80V/MIL.



IEEE 383-1974

Tests to Qualify for DBE - Flame

- **Vertical wire flame test**
- **Vertical tray flame test**

Vertical Wire Flame


Test Procedure

- 22" specimen
- Flame impingement 10" below paper flag
- Flame temp ~ 1530F
- 15 sec flame application
- 15 sec off period
- 5 cycles
- Pass: < 25% flag damage



IEEE 383 VTFT Procedure

- 8 ft ladder type tray
- 12" wide
- Gas burner placed 3" behind tray and 2 ft off the floor
- Theoretical Heat Input 70,000 BTU/hr
- Specimens fill at least center 6" of tray width
- Specimens spaced $\frac{1}{2}$ OD apart
- Flame Exposure 20 minutes
- Allow cable to burn until self-extinguished



IEEE 383 VTFT Requirement

**Cable damage
cannot reach the
top of the
specimens.**

(< 6 feet damage)



1974 to 2003

- **Additional issues, such as**
 - **Synergistic effects**
 - **Factory Splices**
 - **Fire Resistance**
 - **Multiconductor qualification**

IEEE 383-2003

- **Not intended to require re-qualification**
- **Type Testing still preferred**
- **Emphasizes other methods of qualification**
 - **Past operating experience**
 - **Ongoing qualification**
 - **Qualification by analysis**

IEEE 383-2003 - Changes

- Vertical Tray Flame Test procedure removed and refers to IEEE 1202-1991
- Synergistic effects
- Factory splice qualification
- Multiconductor qualification
- Class 1E qualification for normal service must be demonstrated separately from DBE qualification

1202 vs. 383-1974 VTFT Comparison

- Both 70k BTU/hr
- IEEE 1202
 - Increased Tray loading
 - Decreased spacing ($> 1''$ cables)
 - Bundled small diameter cables ($< 0.5''$)
 - Less damage allowed (4.9 ft vs 6 ft)
 - Burner angle (20°)
 - Test Enclosure
 - Forced Ventilation

Tray Loading and Spacing

383

12"


1.2" diameter
4 cables
0.6" spacing



6" min.

1202

1.2" diameter
5 cables
0.5" spacing



~8.5" to 11"

Tray Loading and Spacing

383

12"

0.3" diameter

14 cables



6"

1202

0.3" diameter

10 groups of 3

30 cables




~9" to 11"

Tray Loading


OD = 0.97"



383-74
5 cables



1202
7 cables




**Cable OD
0.31"**


**1202
30 cables
fill = 9.7"**

1202 Test Enclosure


Sketch from
IEEE 1202-2006



45"



72"



59" P/F



383

PVC jacketed
power cable

1202

Class 1E Qualification Program

**for a
Instrumentation, Control, LV Power &
Medium Voltage EPR Insulations**

- 1. Industry Standard Tests**
- 2. LOCA Test**
- 3. Normal Operation Test**
- 4. HELB Test**
- 5. Vertical Tray Flame Test**

Class 1E Qualification Program EPR-N

1. Industry Standard tests

ICEA & UL requirements

1/C: Listed as RHW-2 , XHHW-2, X110

VW-1 & Oil Resistant

M/C: Listed as Type TC

Class 1E Qualification Program MV EPR

1. Industry Standard tests

ICEA S-93-639 & S-94-649

UL 1072

Class 1E Qualification Program EPR-N Insulation

2. LOCA Test Sample selection:

Single Conductors:

#14 AWG (7x) Cu, 0.030" EPR-N

#16 AWG (7x) Cu, 0.025" EPR-N

Six colors



Class 1E

Qualification Program

EPR-N Insulation

2. LOCA Test Sample selection: M/C

**3/C #14 AWG Cu, 0.030" EPR-N, cabled,
binder tape, TS-CPE jacket**

**3/C #14 AWG Cu, 0.030" EPR-N, cabled,
binder tape, CSPE jacket**


**1 Pr #16 AWG Cu, 0.025" EPR-N,
#18AWG drain wire, Cu laminate tape,
XLPO jacket**



Class 1E Qualification Program MV EPR Insulation

2. LOCA Test Sample selection: 1/C

#6 AWG Cu, SC-EPR, 0.115" MV EPR,
SC-EPR, 0.005" Cu tape, cable tapes, TS-
CPE jacket





Class 1E Qualification Program

2. LOCA Test

Non aged specimens

Aged specimens

Radiation – 50 Mrads (gamma)

Thermal - 3 weeks @ 150 C

- 2 weeks @ 165 C

Class 1E Qualification Program

2. LOCA Test

Accident radiation dose - 150 Mrads


Current & voltage loaded

Temp-Pressure-Chem Spray profile

Charging current monitored

Periodic IR measurements

LOCA Profile



ote:

Margins

- **Double peak**
- **Voltage: \emptyset - \emptyset Rated voltage applied \emptyset -grd**
- **Radiation**
 - **Normal aging: 50 Mrads - gamma**
 - **Accident: 150 Mrads - gamma**
- **Thermal Aging: 60 years**

Class 1E Qualification Program

LOCA Test EPR-N Specimens


- **42 1/C wires**
- **Six 3/C cables**
- **Three 1 Pr cables**

LOCA Test MV EPR Specimens

- **Three 1/C cables**

LOCA Test Specimens

- 42 1/C wires
- Six 3/C cables
- Three 1 Pr cables
- Three 1/C cables



Class 1E Qualification Program

3. LOCA Test Results


All samples:

- **Maintained voltage & current**
- **Withstood Post-LOCA Simulation Test**
 - **Straighten & Recoil (40 x OD)**
 - **80 v/mil ac withstand**

Class 1E - Qualification Program

3. Post LOCA Test Results

Post LOCA Long Term Moisture Resistance @90C
#14 AWG 0.030" EPR-N



Class 1E - Qualification Program

3. Post LOCA Test Results

Instrumentation jacket integrity

| Specimen | Jacket Resistance - Megohms @500 Vdc after 1 minute | Charging Current mA @ 600Vac after 1 minute |
|-------------------|---|---|
| Unaged | 3.5 E3 | < 1 mA |
| 3 weeks @ 150C | 1.5 E6 | < 1 mA |
| 2 weeks @ 165C | 4.3 E1 | < 1 mA |

Class 1E Qualification Program

3. Normal Operation Test

Sample selection: **Single Conductors**

#16 AWG (7x) 0.025" EPR-N
six specimens

#6 AWG Cu, SC-EPR, 0.115" MV EPR,
SC-EPR, 0.005" Cu tape, cable tapes,
TS-CPE jacket
three specimens

Class 1E Qualification Program

3. Normal Operation Test

Aging

Radiation – 50 Mrads (gamma)

Thermal – 3 weeks @ 150 C

- 2 weeks @ 165 C

Class 1E Qualification Program

3. Normal Operation Test

Mechanical & Voltage Withstand

Straighten

20 x OD bend

80 volt/mil ac withstand test

Class 1E

Qualification Program

4. HELB Test

Specimens –

- #16 AWG Cu, 0.025" EPR-N
- #6 AWG Cu, SC-EPR, 0.115" MV EPR, SC-EPR, 0.005" Cu tape, cable tapes, TS-CPE jacket

Class 1E

Qualification Program

4. HELB Test

Non-aged & aged specimens

Temp – Press – Chem spray profile


Current & voltage loaded

Charging current monitored



Periodic IR measurements

High Energy Line Break Test Temperature / Time Profile

HELB Temperature Profile



HELB EPR-N Test Specimens



Class 1E Qualification Program

4. HELB Test Results

All samples:

- **Maintained rated voltage & current**
- **Withstood Post-LOCA Simulation Test**
 - **Straighten & Recoil (40 x OD)**
 - **80 v/mil ac withstand**

Class 1E Qualification Program

5. IEEE 1202 VTFT Test Results

600 V Constructions:

- 3/C #14 AWG 0.030" EPR-N, cabled, binder tape, TS-CPE jacket
- 3/C #14 AWG 0.030" EPR-N, cabled, binder tape, CSPE jacket
- 1 Pr #16 AWG 0.025" EPR-N, #18 AWG drain wire, Cu laminate tape, XLPO jacket

Class 1E Qualification Program

5. IEEE 1202 VTFT Test Results

2 kV Constructions:

- 3/C #14 AWG 0.045" EPR-N, cabled, binder tape, TS-CPE jacket**
- 3/C #14 AWG 0.045" EPR-N, cabled, binder tape, CSPE jacket**
- 1/C #6 AWG 0.060" EPR-N**

Class 1E Qualification Program

5. IEEE 1202 VTFT Test Results

5 kV Construction:

**#2/0 AWG Cu, SC-EPR, 0.115" MV EPR,
SC-EPR, 0.005" Cu tape, cable tapes, TS-
CPE jacket**

Qualification Reports

□ **EPR-N**

- **Engineering Report # 526**

“Class 1E Qualification of Okonite FMR-N Insulated Cables For Nuclear Power Generation Stations”

□ **MV EPR**

- **Engineering Report # 527**

“Class 1E Qualification of Okoguard Insulated Cables For Nuclear Power Generation Stations”

Summary

□ IEEE 383-2003

- Re-qualification not required
- Allows other types of qualification
- Addressed '74 to '03 issues
- VTFT (1202) more severe

□ Qualification Test Program

- EPR-N & MV EPR insulations qualified to 383-74 & 383-03 for Normal, LOCA, HELB & IEEE 1202
- 40 and 60 year accelerated aging

Any Questions?

