

i n v e n s y sTM

Operations Management

Recent Equipment Qualification Activity

IEEE SUBCOMMITTEE ON
QUALIFICATION
IEEE/NPEC/SC 2 Meeting 11-1

Presented by Frank W. Kloer, P.E.
06/15-17/11

i n v e n s y sTM
Operations Management

Avantis Eurotherm Foxboro IMServ InFusion SimSci-Esscor Skelta Triconex Wonderware

© 2010 Invensys. All Rights Reserved. The names, logos, and taglines identifying the products and services of Invensys are proprietary marks of Invensys or its subsidiaries. All third party trademarks and service marks are the proprietary marks of their respective owners.

Recent Products subjected to Nuclear Qualification

Safety Video Display Unit (1E VDU)

- Model 5900N SVDU Server
- Model 5910N SVDU Monitor (Rack-mount)
- Model 5920N SVDU Monitor (Panel-mount)

Priority Logic Module (PLM)

- Model 3900N Priority Logic Module
- QNX Version 6

Qualification Basis

EPRI TR-107330 (Hybrid)

IEEE 323 - 2003

USNRC R.G. 1.180, Revision 1

IEEE 1012 1998

Slide 4

Avantis Eurotherm Foxboro IMServ InFusion SimSci-Esscor Skelta Triconex Wonderware

i n v e n s i sTM
Operations Management

Safety Video Display Unit (1E VDU)



SVDU Server 5900N

Safety Video Display Unit (1E VDU)




SVDU Monitor 5920N

Safety Video Display Unit (1E VDU)

- MPU - single-board has 4 GB ECC DDR2 RAM
- Contains two 32 GB SSD SATA SLC hard drives
- Redundant Power Supplies
- Redundant fiber-optic 100 Mbps Ethernet connectivity
- 40° F to 122° F (4.4° C to 50° C), ambient
- Five triaxial Operating Basis Earthquake (OBEs) of 9.8 G peak @ 5% damping, one triaxial Safe Shutdown Earthquake (SSE) of 14 G peak @ 5% damping
- ESD - 8 kV contact, 15 kV air discharge per IEC 61000-4-2
- EMC – USNRC R.G. 1.180, Rev. 1

Slide 7

Priority Logic Module



PLM 3900N

Slide 8

Priority Logic Module

- Inputs
 - Four pairs (A and B) of prioritized Inputs
 - 24 VDC; with a minimum of 50 mA wetting current under all conditions
- Outputs
 - One pair of Switch Outputs (A and B) to the actuating device
 - One pair of Test Switch Outputs (A and B)
- Field Programmable Gate Array (FPGA) processing (For safety and security reasons, the FPGA application logic cannot be reprogrammed in the field.)
- 40° F to 140° F (4.4° C to 60° C), ambient
- Five triaxial Operating Basis Earthquake (OBEs) of 9.8 G peak @ 5% damping, one triaxial Safe Shutdown Earthquake (SSE) of 14 G peak @ 5% damping
- ESD - 8 kV contact, 15 kV air discharge per IEC 61000-4-2
- EMC – USNRC R.G. 1.180, Rev. 1

Slide 9

i n v e n s y sTM

Operations Management