



# HVDC Development Topics

- Core HVDC Technologies
  - Conventional HVDC
  - VSC Based HVDC
- $\pm 800$  kV HVDC
- Cost Comparison of AC & DC Transmission Alternatives
- HVDC Light
  - $\pm 320$  kV, 1100 MW
  - Offshore
  - Multi-terminal & Overhead
- Project Examples

# Core HVDC Technologies







## ■ HVDC Classic

- Current source converters
- Line-commutated thyristor valves
- Requires 50% reactive compensation (35% HF)
- Converter transformers
- Minimum short circuit capacity > 2x converter rating

## ■ HVDC Light



- Voltage source converters
- Self-commutated IGBT valves
- Requires no reactive power compensation (15% HF)
- Standard transformers
- No minimum short circuit capacity, black start

# HVDC Converter Arrangements



## HVDC Classic





- Thyristor valves
- Thyristor modules
- Thyristors
- Line commutated




## HVDC Light

- IGBT valves
- IGBT valve stacks
- StakPaks
- Submodules
- Self commutated


# HVDC Classic Control



# Control of VSC Based HVDC Transmission



# HVDC Light Plant Layout, $\pm 150$ kV, 175- 555 MW




# Cost Comparison of Transmission Alternatives

Alternative	500 kV AC		± 500 kV	± 600 kV	± 800 kV	500 kV AC	765 kV AC
	Two Single Circuits		HVDC Bipole	HVDC Bipole	HVDC Bipole	Double Circuit	Single Circuit
<b>Capital Cost</b>							
Line voltage (kV)	525		500	600	800	525	765
Rated Power (MW)	3000		3000	3000	3000	3000	3000
No. of ac line segments	6					6	3
No. of series capacitors per line segment	2					2	0
Total No. Series Capacitors	12					12	0
Total No. AC or DC Substations	4		2	2	2	4	4
No. Shunt Reactors per ac line segment	2					2	4
Total No. Shunt Reactors	12					12	12
Total No. Transformers	2					2	4
No. of SVC's	3		2	2	2	3	3
No. Shunt Capacitors	0					0	0
HVDC stations & AC substations incl reactive comp	\$366,000,000		\$560,000,000	\$600,000,000	\$625,000,000	\$366,000,000	\$404,000,000
Transmission Line (cost/mile)	\$1,700,000		\$1,400,000	\$1,456,000	\$1,582,000	\$2,720,000	\$3,600,000
Transmission Line R/W (cost/mile)	\$500,000		\$300,000	\$400,000	\$500,000	\$500,000	\$900,000
Total line distance in miles	1,500		750	750	750	750	750
Transmission Line Cost	\$3,300,000,000		\$1,275,000,000	\$1,392,000,000	\$1,561,500,000	\$2,415,000,000	\$3,375,000,000
<b>Total Transmission Cost + 10% contingency</b>	<b>\$4,032,600,000</b>		<b>\$2,018,500,000</b>	<b>\$2,191,200,000</b>	<b>\$2,405,150,000</b>	<b>\$3,059,100,000</b>	<b>\$4,156,900,000</b>
Annual Payment, 30 years @ rate of	10%	\$427,775,177	\$214,120,963	\$232,440,849	\$255,136,504	\$324,507,028	\$440,960,827
Cost per kW-Yr		\$142.59	\$71.37	\$77.48	\$85.05	\$108.17	\$146.99
Cost per MWh @ Utilization Factor of	65%	\$25.04	\$12.53	\$13.61	\$14.94	\$19.00	\$25.81
No of conductors/pole/phase		2	3	3	3	2	2
Conductor (ohms/mile) ac or dc @ temp of:	50	0.0420	0.0364	0.0364	0.0364	0.0420	0.0420
Line/Pole Current (Amps)		1755	3000	2500	1875	1755	1204
Conductor current density (A/mm <sup>2</sup> )		0.610	0.695	0.579	0.435	0.610	0.419
Losses @ full load		291	209	159	109	291	137
Losses at full load in %		9.69%	6.96%	5.29%	3.63%	9.69%	4.56%
Cost of losses @ UF & \$/kW of:	65% \$1,500	\$283,503,864	\$203,705,153	\$154,868,162	\$106,308,654	\$283,503,864	\$133,522,581






# Cost of transmitting 12000 MW 2000 km






# Comparison of overall line design


800 kV




$\pm 600$  kV



1000 kV



$\pm 800$  kV



# Itaipu 600 kV HVDC Line Performance

	Bipole 1						Bipole 2					
	P1 -			P2 +			P3 -			P4 +		
	Trans	Red.V	Perm	Trans	Red.V	Perm	Trans	Red.V	Perm	Trans	Red.V	Perm
1993	0	1	0	8	1	2	2	0	3	2	0	0
1994	3	0	3	3	0	1	1	2	3	3	0	1
1995	4	0	0	3	0	1	0	0	0	3	1	0
1996	3	0	0	5	0	0	0	0	0	5	0	0
1997	5	2	5	0	0	1	0	0	1*	2	0	1*
1998	2	1	0	4	2	2	0	0	1*	1	0	1*
1999	2	0	0	3	0	0	2	0	1	2	0	1
2000	5	0	1	7	0	1	2	0	0	3	0	0
8 year	24	4	9	33	3	8	7	2	7	21	1	2
Ave.	3	0,5	1,13	4,13	0,38	1	0,88	0,25	0,88	2,63	0,13	0,25

**Trans** = 0,659 pole faults / 100km / year

**RedV** = 0,078 pole faults / 100km / year

**Perm** = 0,202 pole faults / 100km / year

\*Line Tower Failures  
total two events

Isokeraunic Level 90 (Foz) to 50 (SP)

**Trans** = Successful restart at full voltage

**RedV** = Successful restart at reduced voltage (450 kV)

**Perm** = Permanent, excluding tower failures



# Itaipu 765 kV AC Line Performance

	765 kVac Transmission Lines								
	Line 1			Line 2			Line 3		
	Trans	Perm	Length	Trans	Perm	Length	Trans	Perm	Length
1995	0	4	891	1	11	891	-	-	0
1996	1	13	891	0	7	891	-	-	0
1997	0	6	891	2	13	891	-	-	0
1998	0	10	891	2	16	891	-	-	0
1999	1	27	891	1	10	891	-	-	0
2000	3	15	891	3	14	891	2	9	602
2001	2	4	891	4	8	891	2	5	915
2002	4	12	891	1	7	891	4	16	915
8 year	11	91	7128	14	86	7128	8	30	2432

**Trans = 0,198 faults / 100km / year**

**Perm = 1,240 faults / 100km / year**

**Trans** = Successful reclose, one attempt

**Perm** = Permanent, excluding tower failures

**Tower Failures due to wind:**

1994 3 both circuits\*

1997 2 both circuits\*

1998 2 both circuits\*

\*total of 3 events

Isokeraunic Level 90 (Foz) to 50 (SP)




# Three Gorges China 3000 MW


The thyristor valve hall



# $\pm 800$ kV, 3600 MW Converter Station



# 800 kV HVDC- one pole



**Exposed to 800 kV dc**

# Long term test circuit for 800 kV HVDC






# Testing for valve hall clearances



# Valve Hall 800 KV HVDC








# HVDC Light rating increase to 1100 MW


- Elements common to existing systems
  - IGBT chip
  - IGBT submodule
  - IGBT StakPak
  - IGBT module or stack
  - Control system
  - Cooling system
  - DC capacitor
- Increased dc current – six submodules per StakPak rather than four
- Increased dc voltage (150 kV to 320 kV)
  - Valve stacks comprised of IGBT modules with 26 positions arranged horizontally
  - Modules connected in series at site to reach rated voltage – elimination of valve enclosures used for the lower voltages
  - DC voltage still lower than that commonly used for conventional HVDC
- Higher ac voltage on ac filter bus – 400 kV
- Development parallels that for conventional HVDC thyristor valves
- Cable and cable accessories type tested to 320 kV, accelerated life tests to be completed this year




# HVDC Converter Development



# Power Ranges HVDC-Classic and HVDC-Light




# Tapping OVHD HVDC with Large VSC Converters



## HVDC Tap

- Reverse power by polarity reversal
- Electronic clearing of dc line faults
- Fast isolation of faulty converters
- Reactive power constraints
- Momentary interruption due to CF at tap
- Limitations on tap rating, location and recovery rate due to stability



## HVDC Light Tap

- Polarity reversal if main link is bidirectional
- Cannot extinguish dc line fault current contribution without special provision, e.g., diode coupling for inverter
- No interruption to main power transfer due to CF at tap
- Less limitations on tap rating and location
- Cascade VSC connection for lower tap rating
- No reactive power constraints
- Improved voltage stability



# Offshore Applications of HVDC Light



## Offshore Wind Farms


- Long cable transmission to shore
- Voltage regulation
- Wind generator excitation power
- Black start

## Oil and Gas Production

- Long cable transmission from shore
- Feed platform load
- Variable speed compressor drives
- Voltage regulation
- Reduced weight and volume
- Reduced emissions
- Greater efficiency
- Troll – no outages since 2005!



# Valhall, BP



## Nyckeldata

- Valhall är BP:s största plattform i Nordsjön
- Under byggnad
- HVDC Light-systemen ska sköta all kraftmatning till plattformen
- Ger betydande miljöfördelar och minskar behovet av personal på plattformen
- 1 x 78 MW, 290 km sjökabel
- Troll: I drift sedan 2005, inga fel!

# Estlink – HVDC Light between Estonia & Finland



<b>Client:</b>	Nordic Energy Link, Estonia
<b>Contract signed:</b>	April 2005
<b>In service:</b>	November 2006
<b>Project duration:</b>	19 months
<b>Capacity:</b>	350 MW, 365 MW low ambient
<b>AC voltage:</b>	330 kV at Harku 400 kV at Espoo
<b>DC voltage:</b>	±150 kV
<b>DC cable length:</b>	2 x 105 km (31 km land)
<b>Converters:</b>	2 level, OPWM
<b>Special features:</b>	Black start Estonia, no diesel
<b>Rationale:</b>	Electricity trade Asynchronous Tie Long cable crossing Dynamic voltage support Black start

# Estlink – full power after 19 months

Last updated: 29 Nov 2006 15:18



## Consumption and production in Finland

Consumption	11433 MW
Production	9483 MW
- hydro power	1484 MW
- nuclear power	2715 MW
- condensing power	881 MW
- district heat back pressure	2391 MW
- industry back pressure	1949 MW
- other production (estimate)	63 MW
Net import/export	1950 MW

## Electricity price in Finland

Elspot price area Finland	41.65 e/MWh
---------------------------	-------------

## Power balance

Production deficit/surplus in Finland	-393 MW
Surplus/deficit, cumulative	-90 MWh
Instantaneous freq. measurement	49.98 Hz
Time deviation	6.93 s

Temperatures in Finland: Helsinki +6°C, Jyväskylä +7°C, Oulu +6°C, Rovaniemi +4°C

# NorNed Cable HVDC Project



**The longest underwater high-voltage cable in the world.**

**Clients:** Statnett and TenneT

**Transmission capacity:**

700 MW

**DC Voltage:**

$\pm 450$  kV

**Length of DC cable:**

2\*580 km

**Water depths:**


Up to 410 m

**Project start:**

January 2005

**Completion time:**

Approx. three years



**Flat Mass-Impregnated submarine cable**


Copper profile wires, 790 mm<sup>2</sup>

**Mass Impregnated submarine cables**

Copper profile wires, 700 mm<sup>2</sup>



# NorNed Cable HVDC Project *Symmetric monopole*



- Rating 600 MW  $\pm$  450 kV
- Low losses 3.7 %
- Continuous 700 MW
- Cable length 580 km
- No sea electrode




# NorNed Cable HVDC Project

Converter valves  $\pm 450$  kV, 700 MW

120 thyristors per single valve

Totally 2880 thyristors





# NorNed kabel HVDC Project

**FMI Cable, 2 x 790 mm<sup>2</sup>**

+/- 450 kV, 700 MW

20 mm insulation

90 kilo/meter

70 km/loading


8 joints 7-10 days/joint

24 hours/day production

2 months after order



# Southlink, Swedish National Grid Company



## Customer need

- Improved security of the electricity supply in South and Central Sweden
- Distance 250 miles

## Alternatives

- 400 kV overhead transmission line
- Turnkey 500 – 700 MW  $\pm$ 300 kV underground HVDC Light system

## Customer benefits with HVDC

- Shorter project time due to easier permitting ( 2 – 3 years )
- Increased power transfer existing a.c. lines ( approx 200 MW)
- Voltage and reactive power control

## Project status

- Final evaluation ongoing. Decision 2007

