



Shaping Tomorrow's
Built Environment Today

Comment 43 of 63 [Expand All](#) | [Collapse All](#) | [Print Comment](#)

Document: BSR/ASHRAE/IES Addendum bg to ANSI/ASHRAE/IES Standard 90.1-2013, Energy Standard for Buildings Except Low-Rise Residential Buildings (First Public Review Draft)

Comment: Remove continuous daylight dimming controls for storage rooms and conference rooms

Commenter Name: Mr Mike Anthony
Affiliation: University of Michigan
Address: 326 E Hoover Ave
 Ann Arbor MI, 48109-1002
Phone: (734)936-1110 **Fax:**
Email: maanthon@umich.edu

Comment Type: Substantive **Commenter Number:** 0003
Section/Subsection Type: Clause **Comment Number:** 001
Section/Subsection Identifier: 9.3.3-1 **Date Submitted:** 9/7/2015 2:20:49 PM
Supportive: No **Comment Status:** Responded To [Withdraw](#)
Approval Date:

Attachments:

Comment Text:

Remove the requirement for continuous daylight dimming controls for school building storage rooms, conference rooms and meeting rooms.

Substantiating Comments:

School building storage rooms, and most conference and meeting rooms do not need continuous daylight dimming controls. This part of this proposal looks like market-making (by lighting control advocates) at its worst.

Comment Responses and Replies

Comment Title	Type	Status	Submitted By	Date Submitted	Reply Deadline	Request	Further Action	Review Action	Commenter Action	Approval Date
Response: Remove continuous daylight dimming controls for storage rooms and conference rooms	Response	Approved	culp@birchpointconsulting.com	02/11/2016	03/12/2016	No		Accepted, in principle (a different response to the issue is proposed)		01/25/2016

The committee has removed the daylighting requirements and does find added clarity in some other proposed changes. These will be incorporated into a revised section on the simplified method(s) that will go out as the 2nd public review and will include all three simplified methods (office, retail, and school) and supporting text.

Approval Method: PC Meeting **Approval Mtg Location:** Orlando

[Reply](#)

A reply to this response must be made on or before **3/12/2016** which is the date specified in the Reply Deadline.