220.2 Definitions

<u>Demonstrated Load.</u> Historical demand watt information recorded over at least a 24-month period for the same type of facility as the one in question, equated to watts/square foot (watts/square meter)

Additional Proposed Changes

File Name

Description Approved

CSA-Groups-CEC-Section-8-Circuit-loading-and-demand-factors.pdf

1

Statement of Problem and Substantiation for Public Input

This is a correlating and necessary definition to accompany a proposal for demonstrated load in a new proposal in Section 220.86.

Submitter Information Verification

Submitter Full Name: Michael Anthony

Organization: Standards Michigan

Affilliation: www.standardsmichigan.com

Street Address:

City: State: Zip:

Submittal Date: Mon Jun 26 06:27:56 EDT 2017

Copyright Assignment

I, Michael Anthony, hereby irrevocably grant and assign to the National Fire Protection Association (NFPA) all and full rights in copyright in this Public Input (including both the Proposed Change and the Statement of Problem and Substantiation). I understand and intend that I acquire no rights, including rights as a joint author, in any publication of the NFPA in which this Public Input in this or another similar or derivative form is used. Except to the extent that I may lack authority to make an assignment of content identified above, I hereby warrant that I am the author of this Public Input and that I have full power and authority to enter into this copyright assignment.

By checking this box I affirm that I am Michael Anthony, and I agree to be legally bound by the above Copyright Assignment and the terms and conditions contained therein. I understand and intend that, by checking this box, I am creating an electronic signature that will, upon my submission of this form, have the same legal force and effect as a handwritten signature

Origin (from sources other than the submitter)

Arkady Tssiserev, Lorne Clark (University of Alberta), Jim Harvey