

Item	CAC Coord.	Section number	CDP Access #	Code Change Number	Hearing Committee	Results	Time	Topic
AB1		IBC 1026.4.1	6640	G003-21 Part 1	E	AS	4/18 pm	Ambulatory care definition
AB1		IFC 805.2, 808.1		G003-21 Part 2	F	AS	5/1 pm	Ambulatory care definition
AB1		IPC 202		G003-21 Part 3	P	AS	4/25 pm	Ambulatory care definition
AB1		IMC 202		G003-21 Part 4	M	AS	4/28 pm	Ambulatory care definition
HC2		IMC 505	6641	M032-21		D	4/28 pm	IMC 505, domestic cooking equipment55
HC3B		IPC 609.3	6642	P102-21		D	4/28 pm	Cold handwashing
		IPC 609.2		P101-21		D	4/26 pm	Water service for hospitals
HC4	PMGCAC	IPC 403.1		P021-21		D	4/26 pm	Plumbing fixtures in Group I
		IPC 403.1		P018-21		D	4/25 pm	Day care
HC5	BCAC	IBC 202, 1010.2		E055-21		D	4/20 am	Man traps
		IBC 1010.2		E051-21		AS	4/20 am	Electric locks
		IBC 1010.2		E052-21		AS	4/20 am	electro-mechanical locking devices
		IBC 202, 1010.2	7456	E043-21		D	4/19 pm	Door latching
		IBC 709.5	7576	FS048-21		AM	4/16 pm	Positive latching on smoke barriers
HC8		IBC 202	6643	G005-21		AM	4/11 pm	Limited assistance definition
HC9		IBC, IFC	6362	F175-21			5/4 pm	BCAC OCC Item 17 Labs
		IFC 202, 322, 903		F069-21		D	5/2 pm	animal housing, including labs

		IFC Chapter 38		G036-21	F		5/4 pm	Labs
		IFC Chapter 38		F176-21			5/4 pm	Labs
HC10		IBC 717.6.2	6644	FS091-21		AM	4/17 am	717.6.2- Fire dampers
K311		IBC 404.6	6723	G062-21		AS	4/12 pm	Vertical openings
K321		IBC 509.1	6732	G128-21		AS	4/13 pm	Incidental use table
K362		IBC 710.4	6733	FS049-21		AS	4/16 pm	Lay in ceilings
K903		IPC 1202.1	6734	P145-21	F			Hazard vulnerability analysis
K905		IFC 5306	6735	F200-21			5/5 am	Signage - medical gas cylinders
K912		IFC 1105.12	6736	F119-21 Part 1	F	D	5/3 pm	Electrical systems - receptacles
K912		IBC 2701.1.1		F119-21 Part 2	G	D	4/14 pm	Electrical systems - receptacles
		IBC 1020.1		E089-21		D	4/20 pm	corridor width
		IBC 1020.3		E091-21		D	4/20 pm	Corridor width
		IBC 1027.2		E100-21		D	4/21 am	exit stairways
		IBC 407.4.4		G071-21	E	AM	4/20 pm	aisles in care suites
		IBC 407.5.5		G072-21	E	D	4/21 am	horizontal assemblies
		IBC 1108.5		E129-21		D	4/21 pm	Assisted toileting and bathing
		IBC 1110.3		E143-21		AS	4/21 pm	Accessible sink exceptions

		IBC 1108.5		E128-21		D	4/21 pm	communication features
		IBC 202, 1210		G174-21		D	4/14 pm	Germicidal irradiation
		IBC 202, 1211		G173-21		AS	4/14 pm	Germicidal irradiation
		ICCPC 202, 1000		PC013-21	G	D	4/14 pm	airborne pathogens
		ICCPC 1101		PC014-21	M	D	4/29 pm	airborne pathogens
		ICCPC 1401.3.8.1		PC016-21	G	D	4/14 pm	secondary power supply
		IFC 903.2.2		F065-21		D	5/2 pm	sprinklers in ambulatory care
		IFC 907.5.2.1.3		F92-21		AS	5/3 am	audible fire alarms in I-1
		IFC 915		F102-21		D	5/3 am	carbon monoxide detection
		IFC 1103.9		F116-21		D	5/3 am	carbon monoxide detection
		IBC 202, 1210		G172-21		D	4/14 am	grab bars at bathtubs in R-4
		IBC 3006.3		G184-21		D	4/14 pm	Elevator hoistways in Group I-1 and I-2
		IBC 714.2.1, 715.2.1		FS059-21		D	4/16 pm	contractor qualifications for Group I-2 fire resistant joint systems
		IBC 308, 310		G042-21		D	4/12 am	Care facilities w/ 5 or fewer people
		IBC Appendix Q		G201-21		D	4/15 am	temporary emergency structures

		IFC 603.5.1		F050-21		D	5/2 pm	RPTs and UL962A
		IMC 403.3.1.1		M021-21		AM	4/28 pm	ASHRAE update to OP ventilation rates.